




Series ISDP Intrinsically Safe Differential Pressure Transmitter


Specifications - Installation and Operating Instructions



DIMENSIONS



OPTIONAL A-438 BRACKET MOUNTING DIAGRAM



SPECIFICATIONS

Service: Air and non-corrosive gases.

Wetted Materials: Ranges 5" and greater: glass, PVC, silicon, alumina ceramic, epoxy, RTV, gold, aluminum, stainless steel and nickel; Ranges 1" and lower: stainless steel, silicone, gold and ceramic.

Housing Materials: Aluminum, glass.

Accuracy: $\pm 0.5\%$ at 77°F (25°C) including hysteresis and repeatability (after 1 hour warm-up).

Stability: $< \pm 1\%$ per year.

Pressure Limits: Ranges ≤ 2.5 in. w.c. = 2 psi;

5": 5 psi; 10": 5 psi; 25": 5 psi; 50": 5 psi; 100": 9 psi.

Temperature Limits: 32 to 161.6°F (0 to 72°C).

Compensated Temperature Limits: 32 to 140°F (0 to 60°C).

Thermal Effects: 0.020%/°F (0.036/°C) from 77°F (25°C).

Power Requirements: 10-35 VDC.

Output Signal: 4-20 mA DC.

Zero & Span Adjustments: Accessible via menus.

Response Time: 250 ms (dampening set to 1).

Display: 4 digit LCD 0.6" height.

Electrical Connections: M12 4 PIN Connector.

Process Connections: 1/8 female NPT.

Enclosure Rating: Designed to meet NEMA 4x (IP66).

Mounting Orientation: Mount unit in horizontal plane.

Size: 4.73" x 4.73" x 3.43" (120 mm x 120 mm x 87.1 mm).

Weight: 2 lb 10 oz (1.19 kg).

Agency Approvals: FM Approved: IS / I, II, III / 1 / ABCDEFG / T4 Ta = 0°C to 72° - 19-443480-50; ENTITY; TYPE 4X (US AND CANADA) I / 0 AEx ia / IIC / T4 Ta = 0°C to 72° - 19-443480-50; ENTITY; TYPE 4X (US) I / 0 / Ex ia / IIC / T4 Ta = 0°C to 72° - 19-443480-50; ENTITY; TYPE 4X (CANADA) CE. CENELEC EN 61326/55024: 2003; IEC 61000-4-2/3/4/6: 2001/2006/2004/2005; CENELEC EN 55011: 2006; 2004/108/EC EMC Directive.

Intrinsic Safety Information

Entity Parameters

Ui = 28VDC

Ii = 93mA

Ci = 22 nF


Li = 400 uH

Pi = 651mW

Notes:

1. Remove power from the instrument before carrying out any servicing.
2. Use only FM approved Associated Apparatus.
3. The earth terminal on the housing must be wired to a local earth ground in the hazardous area.
4. Refer to control drawing 19-443480-50, Page 15, for installation requirements.

M-12 Connector



A-231 M-12 Cable Colors

PIN 1 is Brown (positive)

PIN 3 is Blue (negative)

Use Model A-231 shielded cable with 4 pin Female M-12 connection.

2-WIRE CONNECTION




Fig. C

-----2-Wire Operation- An external power supply delivering 10 - 35 VDC with minimum current capability of 40 mA DC (per transmitter) must be used to power the control loop. See Fig. C for connection of the power supply, transmitter, and receiver. The range of the appropriate receiver load resistance (R_L) for the DC power supply voltage available is expressed by the formula and graph in Fig. D.

POWER SUPPLY VOLTAGE - VDC (2-WIRE CONNECTION)





Fig. D

INSTALLATION

Mount the instrument in a location that will not be subject to excessive temperature, shock or vibration.

Pressure Connections


Use 1/8" male NPT fittings. When tightening fittings, grasp the brass fitting on the ISDP with a 1/2" wrench to prevent the fitting on the ISDP from turning.



KEY FUNCTIONS


	HOME POSITION FUNCTION	MAIN MENU FUNCTION	SUB MENU FUNCTION
 MENU	Allows access to the menus	Return to home position	Return to previous menu
 UP ARROW		Sequences through menus	Increments a value
 DOWN ARROW		Sequences through menus	Decrements a value
 ENTER	Displays full scale range of unit	Enter into SUB MENU	Changes a value or setting. Press ENTER and display will blink. Adjust with UP or DOWN arrows. Press ENTER to store. Display will stop blinking. Peak/Valley SUB MENU resets display to present value.


MENU MAP



CONTINUED →





Model Chart	
Model	Range
ISDP-002	0-0.25"
ISDP-004	0-1" WC
ISDP-005	0-2.5" WC
ISDP-006	0-5" WC
ISDP-007	0-10" WC
IDSP-008	0-25" WC
ISDP-009	0-50" WC
ISDP-010	0-100" WC
ISDP-011	-0.1/+0.1" WC
ISDP-012	-0.25/+0.25" WC
ISDP-013	-0.5/+0.5" WC
ISDP-014	-1.0/+1.0" WC
ISDP-015	-2.5/+2.5" WC
ISDP-016	-5.0/+5.0" WC
ISDP-017	-10/+10" WC

Main Menu Selections (Upper Right Display Reads MENU)

- SECr Security - Lock out access to menus and settings.
- OPER Operation - Selection of Pressure, Velocity or Flow and corresponding engineering units.
- diS Display - Monitor and adjust display related settings: Peak, Valley, display resolution, % output and dampening.
- ADJ Advanced functions - Modify advanced function parameters, transmitter output scaling, and calibration.

MAIN MENUS and SUB MENU

SEC- (Security) MAIN MENU

SEC- is the only SUB MENU in the security MENU. When the security SUB MENU is selected, the present security level is displayed in the upper right hand display. To change the security level, adjust the number displayed to the number shown in the following table for the desired security level.

Security Level Displayed	Access	Password Value to Enter
1	All menus access	10
2	All settings locked	70

The password values shown in the table cannot be altered, so retain a copy of these pages for future reference.

OPER (Operation) MAIN MENU

The OPER MENU selects the measurement type of the instrument. The SUB MENUS are:

PRES - Pressure

KFAC - K Factor

XDIM - X Dimension

VEL - Velocity

AREA - Area

YDIM - Y Dimension

FLO - Flow

DIA - Diameter

If the instrument is set for Velocity, the OPER MENU will have an additional KFAC SUB MENU. If the instrument is set for Flow, the OPER MENU will have additional KFAC and AREA SUB MENUS. These will be discussed under Velocity and Flow. When scrolling through the OPER SUB MENUS, the measurement type the unit is currently set for will show the units in the upper right display. The other measurement types will have a blank upper right display.



PrES (Pressure) SUB MENU

For pressure measurement, the following units are available:

- | | |
|------------------------------------|-------------------------------|
| INWC - Inches of water column | MMHG - Millimeters of mercury |
| FTWC - Feet of water column | MBAR - Millibar |
| MMWC - Millimeters of water column | PA - Pascal |
| CMWC - Centimeters of water column | KPA - Kilopascals |
| PSI - Pounds per square inch | HPA - Hectopascals |
| INHG - Inches of mercury | OZIN - Ounce inches |

Table 1 Pressure Range vs. Available Units

INWC	FTWC	MMWC	CMWC	PSI	INHG	MMHG	MBAR	PA	KPA	HPA	OZIN
.1000		2.540	.2540			.1868	.2491	24.91		.2491	
.2500		6.350	.6350			.4671	.6227	62.27		.6227	.1445
.5000		12.70	1.270			.9342	1.245	124.5	.1245	1.245	.2890
1.000		25.40	2.540			1.868	2.491	249.1	.2491	2.491	.5780
2.500	.2083	63.50	6.350		.1839	4.671	6.227	622.7	.6227	6.227	1.445
5.000	.4167	127.0	12.70	.1806	.3678	9.342	12.45	1245	1.245	12.45	2.890
10.00	.8333	254.0	25.40	.3613	.7356	18.68	24.91	2491	2.491	24.91	5.780
25.00	2.083	635.0	63.50	.9032	1.839	46.71	62.27	6227	6.227	62.27	14.45
50.00	4.167	1270	127.0	1.806	3.678	93.42	124.5		12.45	124.5	28.90
100.0	8.333	2540	254.0	3.613	7.356	186.8	249.1		24.91	249.1	57.80

NOTE: OVF (over flow) or UVF (under flow) will appear when the ranges have been exceeded above or below full scale by 2%.

VEL (Velocity) SUB MENU

For velocity measurement, the following units are available:

- SFPM - Standard feet per minute
- M/S - Meters per second

Table 2 Available Velocity Ranges

INPUT RANGE INWC	SFPM RANGE	M/S RANGE
0 - 0.1	0 - 1266	0 - 6.431
0 - 0.25	0 - 2002	0 - 10.17
0 - 0.5	0 - 2832	0 - 14.39
0 - 1	0 - 4004	0 - 20.35
0 - 2.5	0 - 6332	0 - 32.17
0 - 5	0 - 8954	0 - 45.48
0 - 10	0 - 12.66 x IK	0 - 64.33
0 - 25	0 - 20.02 x IK	0 - 101.7

NOTE: Air velocity and flow readings are based upon standard dry air conditions with an ambient temperature of 70°F and a barometric pressure of 29.92 INHG.

FLO (Flow) SUB MENU

For flow measurements the following units are available:

SCFM - Standard cubic feet per minute

m³/H - Cubic meters per hour

FLO_r (Flow Range) SUB MENU

LO - 99.99 x 1K flow range

HI - 999.9 x 1K flow range

Tables 3 -6 show the flow ranges available, and the maximum duct size that can be set for each input range.

Table 3

FLO_r = LO **Maximum Duct Size (English)**

RANGE IN WC	SCFM RANGE	MAX. DUCT SIZE, SQ. FT.
0.1	99.99 x 1K	78.9
0.25	99.99 x 1K	49.9
0.5	99.99 x 1K	35.3
1	99.99 x 1K	24.9
2.5	99.99 x 1K	15.7
5	99.99 x 1K	11.1
10	99.99 x 1K	7.8
25	99.99 x 1K	4.9

Table 4

FLO_r = HI **Maximum Duct Size (English)**

RANGE IN WC	SCFM RANGE	MAX. DUCT SIZE, SQ. FT.
0.1	999.9 x 1K	789.8
0.25	999.9 x 1K	499.5
0.5	999.9 x 1K	353.1
1	999.9 x 1K	249.7
2.5	999.9 x 1K	157.9
5	999.9 x 1K	111.7
10	999.9 x 1K	78.9
25	999.9 x 1K	49.9

Table 5

FLO_r = LO **Maximum Duct Size (Metric)**

RANGE IN WC	m ³ /Hr RANGE	MAX. DUCT SIZE M ²
0.1	99.99 x 1K	4.32
0.25	99.99 x 1K	2.73
0.5	99.99 x 1K	1.93
1	99.99 x 1K	1.37
2.5	99.99 x 1K	0.86
5	99.99 x 1K	0.61
10	99.99 x 1K	0.43
25	99.99 x 1K	0.27

Table 6

FLO_r = HI **Maximum Duct Size (Metric)**

RANGE IN WC	m ³ /Hr Range	MAX. DUCT SIZE, M ²
0.1	999.9 x 1K	43.19
0.25	999.9 x 1K	27.31
0.5	999.9 x 1K	19.3
1	999.9 x 1K	13.64
2.5	999.9 x 1K	8.63
5	999.9 x 1K	6.10
10	999.9 x 1K	4.31
25	999.9 x 1K	2.73

KFAC SUB MENU


KFAC K Factor - becomes accessible if the instrument is set for Velocity or Flow. When the Digihelic® II Controller is used with a Pitot tube, the manufacturer may specify a K Factor. The adjustment range is 0.01 to 2.00. The factory setting is 1.

AREA, DIA, XDIM and YDIM SUB MENUS

These SUB MENUS become accessible if the instrument is set for flow. When measuring flow, the area of the duct must be specified. Tables 3 and 4 show the input range vs maximum flow and duct size. For a rectangular duct the maximum size is specified in square feet or meters. For a circular duct the maximum size is specified as the diameter. X, Y and circular dimensions are entered in feet with 0.01 foot resolution for FLOW = LO and 0.1 foot resolution for FLOW = HI, or entered in millimeters with 1 millimeter resolution.

AREA - Area, select CIRC for a circular duct or RECT for a rectangular duct. If a circular duct is selected, the DIA SUB MENU will be activated. If a rectangular duct is selected, the XDIM and YDIM SUB MENUS will be activated.

DIA - Diameter, enter the diameter of a duct
XDIM - Enter the "X" dimension of a duct
YDIM - Enter the "Y" dimension of a duct



d.S (Display) MAIN MENU

PEAK - Peak value	RESO - Resolution
VALV - Valley value	PdS - Process display
ZERO - Zero	DAMP - Dampening level

PEAK (Peak) SUB MENU

The Peak feature stores the highest pressure reading the instrument has measured since the last reset or power up. At power up PEAK is reset to the present pressure reading. To manually reset the PEAK value, press the ENTER key while in the PEAK SUB MENU.

VALV (Valley) SUB MENU

The valley feature stores the lowest pressure reading the instrument has measured since the last reset or power up. At power up VALV is reset to the present pressure reading. To manually reset the VALV value, press the ENTER key while in the VALV SUB MENU.

rES0 (Resolution) SUB MENU

The Series ISDP Controller is capable of displaying four digits of resolution.

However, at very low pressures the instability of the pressure may cause fluctuations in the least significant digit causing the least significant digit to be of little value.

Three digit resolution (3DIG) can only be active when there is at least one digit to the right of a decimal.

3DIG - Set display for 3 digit resolution

4DIG - Set display for 4 digit resolution

Pd.5 (Process Display) SUB MENU

STD - Display reads pressure, velocity, or flow values

PCT - Display reads % of full scale value

When the display is reading percent, PCT is displayed in the upper right of the display. The percent display is only available in pressure operation.

DAMP (Dampening) SUB MENU

Adjust from 1-16

Dampening stabilizes the display from instabilities due to things such as vibration and excessive pressure fluctuations. The dampening setting adjusts the amount of readings that are averaged for each display update. Adjust the dampening value until the display reads a stable value for the application.

PdU (Advanced) MAIN MENU

POL - Process output low

POH - Process output high

ZERO - Zero calibration

SPAN - Span calibration

POL and POH (Process Output Low and High) SUB MENUS

This feature is used in pressure operation only.

Process output low and high are used to scale the 4-20 mA output. Set POL to the desired display reading for 4mA output, and set POH to the desired display reading for 20 mA output. POH must be higher than POL. POL may be adjusted 2% BELOW minimum scale up to POH. POH may be adjusted from POL to 2% ABOVE maximum scale.

ZERO and SPAN (Calibration of Zero and Span) SUB MENUS

The lower display reads CAL in this mode.

ZERO Calibration

NOTE: For accurate calibration, DO NOT apply any pressure when performing this function.


With the display reading ZERO, press the ENTER key. The upper display will blink. Press ENTER again to complete the zeroing of the instrument or press the MENU key to cancel.

SPAN Calibration

_____ With the display set to SPAN, apply full scale pressure to the unit. Press the ENTER key. The upper display will blink. Press ENTER again to complete the calibration or press the MENU key to cancel.

Maintenance

Upon final installation of the Series ISDP intrinsically Safe Differential Pressure Transmitter, no routine maintenance is required. The Series ISDP is not field serviceable and should not be returned if repair is needed (field repair should not be attempted and may void warranty). Be sure to include a brief description of the problem plus any relevant application notes. Contact customer service to receive a return goods authorization number before shipping.



1. THE INTRINSIC SAFETY ENTITY CONCEPT ALLOWS THE INTERCONNECTION OF TWO FM APPROVED INTRINSICALLY SAFE DEVICES WITH ENTITY PARAMETERS NOT SPECIFICALLY EXAMINED IN COMBINATION AS A SYSTEM WHEN:

$$V_{oc} OR U_{io} OR V_{r} \leq V_{max}, I_{sc} OR I_{o} \leq I_{max}, C_{a} OR C_{o} \geq C + C_{cable}, L_{a} OR L_{o} \geq L_{i} + L_{cable}, P_{o} \leq P_{i}$$

2. EQUIPMENT CONNECTED TO THE ASSOCIATED APPARATUS MUST NOT USE OR GENERATE MORE THAN 250 Vrms OR VDC.

3. DIVISION 1 HAZARDOUS (CLASSIFIED) LOCATIONS IN INSTALLATIONS MUST BE IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE (NFPA 70, ARTICLE 504; ZONE 0 HAZARDOUS LOCATIONS MUST BE IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE (NFPA 70, ARTICLE 505; IN U.S. INSTALLATIONS MUST BE IN ACCORDANCE WITH THE CANADIAN ELECTRICAL CODE (CSA C22.1, PART 1, APPENDIX F; IN CANADA. ALL INSTALLATIONS MUST BE IN ACCORDANCE WITH ISEA RP-12.6.

4. NO REVISIONS WITHOUT PRIOR APPROVAL FROM FM RESEARCH.

5. THE ASSOCIATED APPARATUS MANUFACTURERS INSTALLATION INSTRUCTIONS MUST BE FOLLOWED WHEN INSTALLING THIS EQUIPMENT.

6. WARNING - ENCLOSURE PARTS ARE CONSTRUCTED OF ALUMINUM. ENCLOSURE MUST BE PROTECTED FROM MECHANICAL FRICTION AND IMPACT WITH IRON/STEEL TO PREVENT IGNITION CAPABLE SPARKS.

7. SUBSTITUTION OF PARTS MAY IMPAIR INTRINSIC SAFETY. RETURN TO MANUFACTURER FOR ANY REPAIRS.

8. ADDITIONAL SUFFIXES AT (ALUMINUM TAG), COO (CERTIFICATE OF ORIGIN), FC (FACTORY CALIBRATION CERTIFICATE), NIST (NIST TRACEABLE)

CRITICAL DIMENSION
 STANDARD TOLERANCES UNLESS NOTED:
 ALL DECIMAL DIMENSIONS ± .005
 ALL ANGLES ± 1°

F M C O N T R O L D R A W I N G
 SCALE 1:1

4	UPDATE TO ZONE: PER DWM 06-11-14 ECR35481	DATE	01-02-08	NAME	FM CONTROL DRAWING ISDP	MATERIAL	FINISH	
3	REVISED NOTES TO ADD CANADIAN ELECTRICAL CODE PER ECR 12508	DATE	05-05-09	BY	KAS			
2	ADDED CLASS I AND II RATINGS PER ECR 125154	DATE	04-08	BY	CAR			
1	CLASS I AND CLASS II RATINGS REPRODUCED PER ECR 125154	DATE	01-15-08	BY	LRR			
NO.	CHANGES							
					ACAD0002			
							3	
<p>DWYER INSTRUMENTS, INC. MICHIGAN CITY, INDIANA 46360, U.S.A.</p>							<p>FR. NO. 19-443480-50</p>	

NOTE: This drawing and the principles and elements of design embodied therein are the exclusive property of DWYER INSTRUMENTS, INC. and are not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the written consent of DWYER INSTRUMENTS, INC.